

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / 27

Dated: 06 / 01 / 2017

FIRE SAFETY CERTIFICATE

Certified that the **Queen Mary's School Northend** located at **Model Town-III, Delhi-110009** comprised of Ground and 03 upper floors with separate basement owned/ occupied by Queen Mary's School Northend was granted Fire Safety Certificate vide this department letter no. F-6/DFS/MS/school/2012/4743 dated 21.12.2012, have deemed complied with the fire prevention and fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 20.12.2016 in the presence of **Mrs. Anupma Singh/Principal** and that the building/ premises is fit for **occupancy class "Group B Educational"** with effect from**06.01.2017**... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on**06.01.2017**..... at New Delhi


(Atul Gang)
Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Director, Queen Mary;s School Northend, Model Town-III, Delhi-110009.




Queen Mary's School, Northend

(A minority institution run by the Helen Jerwood Memorial Education Society of the Diocese of Delhi, Church of North India.)

Plot No. 4-A, Model Town-III, Delhi – 110009, Ph # 27676626/36, Email: info@qmsmodeltown.com

(Recognized by The Directorate of Education, Delhi & Affiliated to C.B.S.E.)

Ref. No. QMS/Fire Deptt/2020/ 279



06/03/2020

The Chief Fire Officer

Delhi Fire Service

Headquarters: Delhi Fire Service

Connaught Place,

New Delhi – 110001

Subject: Renewal of Fire Safety Certificate for Queen Mary's School, Northend, Model Town, Delhi.

Reference No: Fire Safety Certificate No. F6/DFS/MS/2016/27 .

Sir,

With reference to the above stated subject we request you to kindly renew the Fire Safety Certificate issued to Queen Mary's School Northend, Model Town, Delhi at the earliest.

Thanking you

Yours sincerely

Manager Principal
Queen Mary's School
Northend Model Town,
DELHI-110009
Mrs. Anupma Singh
Principal-Manager

Encl: Copy of Fire Safety Certificate