




DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT

Sample ID	Ref. No. D.J.B/DTQC/Wzd./2024-25/Paid-115-116		
Location /Address of Sample	Queen Mary's School, Northend, Plot No. 4-A, Model Town-III, Delhi-110009		
Letter Reference No.	QMS/DJB/2024/121	Ref. Letter Date	07.08.2024
Challan No.	141	Challan Date	14.08.2024
Sample Collection date	17.08.2024	Analysis start date	17.08.2024
Any other Information	--	Analysis end date	19.08.2024
		Reporting date	20.08.2024

TEST RESULTS

S.No.	Parameters	Unit	As per the IS 10500		Inlet (Ground floor)	Outlet (1 Floor)
			Acceptable limit	Permissible limit		
1	Colour	CU	5 (Max)	15 (Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	3.7	3.2
4	pH Value	--	6.5-8.5	No relaxation	7.29	7.27
5	Electrical Conductivity	µS/cm	-	-	270	268
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	176	174
7	Total Alkalinity	mg/L	200(Max)	600(Max)	66	66
8	Total Hardness	mg/L	200(Max)	600(Max)	124	122
9	Calcium as Ca	mg/L	75(Max)	200(Max)	42	41
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	5	5
11	Iron	mg/L	1.0(Max)	No relaxation	0.08	0.08
12	Chloride	mg/L	250(Max)	1000(Max)	27	26
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.43	0.41
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	3.84	3.76
16	Sulphate	mg/L	200(Max)	400(Max)	17.8	17.4
17	Residual Chlorine	mg/L	0.2 (Min.)	1.0(Max)	0.70	0.64
18	Coliform Count at 37 ⁰ (MPN)	/100 mL	Absent	No relaxation	0	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: For the tested parameters water samples conform IS specification and can be considered for drinking purpose. Also, samples collected from II, III & IV floor for bacteriological examination found satisfactory.

Tested by
Lab.Tech.

Verified by
Asstt. Chemist

Authorized by
Chemist /ACWA(WZD)
Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad



MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE
16 RAJ PUR ROAD, DELHI – 110054



DHO/CLZ/2024/1144

Dated: 05/9/24

SCHOOL HEALTH CERTIFICATE

NAME OF THE SCHOOL

: M/S Queen Mary's School, Northend
at Plot No-4-A, Model Town-III, Delhi- 110009

No of Student

: GIRLS- 3267, TOTAL-3267

: No of Staff Members

: 159

: Date of Inspection

: 30.08.2024

- Rooms are having properly white washed, ventilated and having adequate lighting.
- Drinking water: Delhi Jal Board-Water supply with RO fitted water coolers are installed at each floor for student.
- No of Class Rooms : 119
- No of Toilets : Girls- 80, Staff-13- Total- 93

Sanitation & Hygiene

: General sanitation and hygiene are properly maintained in the school and is satisfactory from Health point of view.

In view of the above submissions this health certificate is being issued in favor of the school by undersigned, after being fully satisfied and having **NO OBJECTION FROM HEALTH POINT OF VIEW.**

The above certificate is valid for one year from date of issue.

Principal

M/S Queen Mary's School, Northend
at Plot No-4-A, Model Town-III, Delhi- 110009.

Dy. Health Officer

Civil Lines Zone

Deputy Health Officer

Civil Lines Zone

Municipal Corporation of Delhi
16, Rajpur Road, Delhi-110054

Principal

Queen Mary's School
Northend Model Town,
DELHI-110009